



Certificate of Analysis

Lab Sample No.: 23C0604-01

Name: Eagle Mountain City (DW)	Sample Date: 3/8/2023 9:21 AM
Sample Site: Well #5	Receipt Date: 3/8/2023 12:40 PM
Comments:	Sampler: Jordan Nielson
Sample Matrix: Drinking Water	Project:
PO Number:	System No.: UTAH25142
Source Code: WS006	Sample Point: WS006
	Report to State: N

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Calculations								
Hardness, Total as CaCO3	593		1.32	mg/L	SM 2340 B	03/09/2023	03/09/2023	
Inorganic								
Total Dissolved Solids (TDS)	948	1000	20	mg/L	SM 2540 C	03/09/2023	03/09/2023	
Metals								
Calcium, Total	149		0.2	mg/L	EPA 200.7	03/09/2023	03/09/2023	
Magnesium, Total	53.4		0.2	mg/L	EPA 200.7	03/09/2023	03/09/2023	